



FORM - D

FORM OF LICENCE UNDER SUB-SECTION (1) OF SECTION 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) ACT, 1965 (TAMIL NADU ACT 13 OF 1965) REFERRED TO IN RULE 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

LICENCE

Licence No. TN-8720220607109

Date: 29-06-2022

Public Building Licence is hereby granted to **Thiru Muthuraj** son of Thiru Thirumalaikolunthu now residing at 15/2E, Ammapettai cee dee yes chennaipattinam NELLIKUPPAM Revenue Village, THIRUPPORUR Taluk, Chengalpattu District - 603108 of Tamil Nadu State for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder,

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building (Door number, Street Number & Name of the Place)	Purpose for which the building is licensed to be used as public building	Number of persons to be accommodated
360 Cee dee yes public school ammapet NELLIKUPPAM, THIRUPPORUR, Chengalpattu, Tamil Nadu, 603108	School (including tutorial school)	1500

Fee paid Rs. 75.0 vide Challan No: 20220603002735, Dated: 03-06-2022

The Period of validity of the licence shall be from the 29-06-2022 to the 28-06-2025 inclusive

Signature valid

Digitally signed by RAJAN SHANMUGAM
Date: 30/06/2022 07:11:21 IST

District: Chengalpattu

LICENCE ISSUING AUTHORITY

This certificate is digitally signed and does not require stamp / signature in original.

CeeDeeYes Public School
No: 360, Chennai Pattinam,
Thirupporur Ittalur Nellikuppam Road,
Ammappettai, Thirupporur Taluk,
Chengalpattu District - 603 108.



Genuineness of the certificate can be verified by:

(a) Keying in the unique certificate number TN-8720220607109 in the URL <https://tnedistrict.tn.gov.in/tneda/VerifyCerti.xhtml>.

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.

Certificate validity period : 29-06-2022 to 28-06-2025

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT
Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012


Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam - 631002
Off: #4, Vanthavasi Road,
Gandhi nagar,
Kanchipuram - 631501
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

**STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SPECIAL SCHOOL
STATEMENT ACCOMPANYING FORM - A**

1. Name of the School and Door no of the Building : **CEE DEE YES PUBLIC SCHOOL**
Plot No. 360, Thiruporur Illalur - Nellikuppam Road, Ammapettai,
Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108.
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S.F. Nos. 380/1,3A,3B, 379/1,5,8,10,14,16,15A,15B,11A,12B,13,9,4,2,3, 475, 360/9A,9B,9C, 476, 382/1,2,378/1,4,5,6,7B,7,8,2,3, 383/2,1,3-9,11-14 384/14,15,13,12,5,9,6,8A,8B,10,11,4,1,2,3, 385/3C2,1A,1B3,1C,2C,2A,2D, 1B1,1B2,386/1C,1B,1A,387/51I
Plot No. 360, Thiruporur Illalur - Nellikuppam Road, Ammapettai,
Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108.
3. Year of construction : Ground, First & Second Floors: RCC : 2011
4. Approximates cost of construction as per current rate : Rs. 1045.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational Purpose
6. Purpose for which the building has hitherto been used : Educational Purpose
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under
(i) Foundation : RCC Column & Footing
(ii) Basement : RCC Column, Plinth Beam & Hollow Blocks
(iii) Superstructure : RCC Column & Hollow Blocks
(iv) Floor & Roof are to be given : Flooring: Marble & Vitrified Tiles
Roof : RCC Slab
8. Period for which the license is require : May be issued from 01.06.2022 to 31.05.2025
(For Three years only)
9. Number of persons to be accommodated : **One Thousand Five Hundred (1500) Pupils only**
Refer "ANNEXURE" to this

Place : Kancheepuram

Date : 26.05.2022


Signature of the Correspondent


Signature of the Engineer
Er. D. NATARAJAN, B.E.,(CIVIL),M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312


மரம் வளர்ப்போம்.

மழை பெறுவோம்

ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.



Signature of the Correspondent

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam - 631002
Off: #4, Vanthavasi Road,
Gandhi nagar,
Kanchipuram - 631501
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM - B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

CEE DEE YES PUBLIC SCHOOL, NELLIKUPPAM VILLAGE

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.


1. **Foundation:**

- | | | |
|------|--|-------------------|
| i. | Depth below ground level | : 6.5ft below G.L |
| ii. | Nature of soil met out in the foundation | : Sandy Soil |
| iii. | Pressure at foundation | : 12 tones / Sq.m |
| iv. | Probable safe bearing capacity of the foundation | : 18 tones / Sq.m |


2. **Superstructure:**

- | | | | |
|-----|--|---|-------------------------------|
| i. | Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 35 Kg / Sq.cm | b) Masonry : 08 tones / Sq.m. |
| ii. | Nature of masonry and concrete And its safe permissible stress | : Brick masonry in cm: 30 tones / Sq.m. | R.C.C : 40 Kg / Sq.cm. |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.06.2022 to 31.05.2025.



Signature of the Correspondent


Signature of the Engineer
Er. D. NATARAJAN, B.E.(CIVIL),M.I.E.,
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
 STRUCTURAL ENGINEER, CHARTERED ENGINEER
 REGISTERED&APPROVED ENGINEER
 BY THE BOARD OF ENGINEERS, TAMIL NADU.
 PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT
 Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3rd Street, S.S.Nagar.
 Palanipet, Arakkonam – 631002

Off: #4, Vanthavasi Road,
 Gandhi nagar,
 Kanchipuram - 631501

Cell: 9443106470, 8056631312
 Email : dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS


CEE DEE YES PUBLIC SCHOOL, NELLIKUPPAM VILLAGE

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.


Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
CEE DEE YES PUBLIC SCHOOL Plot No. 360, Thiruporur Illalur - Nellikuppam Road Ammappettai, Nellikuppam Village, Thiruporur Taluk Chengalpattu District - 603108.	Ground, First & Second Floor: RCC : 10 Years	Rs. 1045.00 Lakhs	Ground Floor +2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational Purpose	License may be issued for the period of Three Years from 01.06.2022 to 31.05.2025	1500 Pupils only	Building is structurally sound

X 

Signature of the Correspondent



Er. D. NATARAJAN, B.E.,(CIVIL) MIE
 Chartered Engineer,
 Panel Engineer Class 1A
 Kanchipuram District
 # 4, Vanthavasi Road,
 Gandhi Nagar,
 Kanchipuram - 631 501.
 Cell: 94431 06470, 8056631312

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS 1A, KANCHEEPURAM DISTRICT

Res: 50-A,3rd Street, S.S.Nagar,
Palanipet, Arakkonam - 631002

Off: #4, Vanthavasi Road,
Gandhi nagar,
Kanchipuram - 631501

Cell: 9443106470, 8056631312
Email: dnatarajan8@gmail.com


BUILDING COMPLETION CERTIFICATE


This is to certify that the below mentioned building was completed in all respect as per the prescribed and approved plan, belongs to **CEE DEE YES PUBLIC SCHOOL**, Illalur - Nellikuppam Road, Ammapettai, Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108 as detail below.

1. Name of the School and Door no of the Building : **CEE DEE YES PUBLIC SCHOOL**
Plot No. 360, Thiruporur Illalur - Nellikuppam Road, Ammapettai Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108.
- 2 Location (Street No. Ward No.) Name of place, i.e. Corporation, Municipality / Panchayat Union /Panchayat/Township/Cantonment : S.F. Nos. 380/1,3A,3B, 379/1, 5, 8, 10, 14, 16, 15A, 15B, 11A, 12B, 13, 9,4,2,3, 475, 360/9A,9B,9C, 476, 382/1, 2, 378/1, 4, 5, 6, 7B, 7, 8, 2, 3, 383/2,1,3-9, 11-14, 384/14, 15, 13, 12, 5,9,6,8A,8B,10,11,4,1,2,3, 385/3C2, 1A, 1B3, 1C, 2C, 2A,2D, 1B1,1B2,386/1C,1B,1A,387/511
Plot No. 360, Thiruporur Illalur - Nellikuppam Road, Ammapettai, Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108.
3. Nature & specifications of Building : RCC Framed Structure
a) R.C.C. 1:1:2 in Column Foundations, Plinth Beam, Roof Beam and Roof Slab etc.
b)Basement Height -4' - 0"
c)Brick Work in cm. 1:6
d)Provided proper R.C.C. 1:1:2 in Roof Slab, Lintel, Beam and Sunshade etc.,
e)Ceiling Plastering in cm. 1:3.
f) Vitrified Tiles in cm 1:5
4. Amenities Provided : a) Concealed Electrification
b) Water Supply and Sanitary Arrangements
c) Septic Tank, Bore Well & OHT, Motor etc.
d) Stair Case
5. Construction Area of the Building :

Name of the Building	Area Schedule of the Building in Sq.Mt.
Ground, First & Second Floors: RCC : 2011	7854.29 Sq.Mt.

6. Documents Reference : Prescribed Plan
As per Registered Document
7. Future Life of Building : 50 Years




Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312

APPENDIX X


BUILDING SAFETY CERTIFICATE

No. 11/PE-KANCHEEPURAM

Dated: 26.05.2022

Certified that the **CEE DEE YES PUBLIC SCHOOL**, Illalur - Nellikuppam Road, Ammapettai, Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108, comprised of Ground, First & Second Floor owned/occupied by **CEE DEE YES PUBLIC SCHOOL**, Illalur - Nellikuppam Road, Ammapettai, Nellikuppam Village, Thiruporur Taluk, Chengalpattu District - 603108, have complied with the Building Bye Laws in accordance with rule of State/UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on **23.05.2022** in the presence of **Thiru. T. Muthuraj, Manager, CEE DEE YES PUBLIC SCHOOL**, and that the said above building/premises is safe and fit for running School with effect from **01.06.2022** for a period of Three years in accordance with rules.

Issued on **26.05.2022** at Kancheepuram by

x 


Signature with Seal:
Er. D. NATARAJAN, B.E. (CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312